

IMPORTANT INFORMATION TO READ and RETURN

Installation Requirements for a Whitley H35 Hypoxystation

Thank you for choosing one of our products for your laboratory. To enable our engineers to perform an efficient, trouble-free installation please study, complete and fax this form to us on **01274 531197**. Should you have any questions, please do not hesitate to contact us, as we are here to help. When we have received the completed form, our Service Department will contact you to arrange a mutually convenient installation date.

**The following information represents the ideal requirement.
Please contact us IMMEDIATELY if your intended location does not match this specification.**



Access Requirements

For access, the dimensions below should be taken into account when checking the size of doorways, lifts, stairs, etc.

Space Requirements

The weight of the equipment is 105kg. If bench mounted, the bench allocated must be flat, level and of sufficient size to support the base fully.

External Dimensions*

Width	Depth	Height
<i>mm</i>	<i>mm</i>	<i>mm</i>
1255	720	710

* Please Note:

In addition to the dimensions noted above, allow a localised protrusion of 90mm at rear to accommodate condenser bottle, bracket, gas and electrical supplies. If benchmounted, a further minimum clearance of 500mm is required above the unit and a minimum clearance of 200mm at the left hand side of the unit is required for user/service access.

Gas Requirements

The incoming gas supplies must be terminated near the right hand side of the main chamber and fitted with leak-proof taps and pressure gauges.


The gas lines to which the equipment is attached are the responsibility of the user and should be constructed, tested and maintained to the standards specified within the British Compressed Gasses Association (BCGA) Code of Practice CP4 (or international equivalent). Gas lines previously used for flammable gases must be purged prior to re-use.

Regulators should be fitted in accordance with the information contained in the table below and the various pressures strictly adhered to.

Gas Type	Connection Details	Cylinder Regulator Required	Regulator Outlet Range	Flow Rate
CO ₂	¼ BSP male fitting or connection for 6mm Polyurethane Tubing CO ₂ Regulator – Two Stage – order Code A00056	Two stage	4-6 bar (60-90 psi)	Minimum 10 litres per minute (Dynamic)
Air	¼ BSP male fitting or connection for 6mm Polyurethane Tubing Air Regulator – Two Stage – order Code – A01554	Two stage	4-6 bar (60-90 psi)	Minimum 10 litres per minute (Dynamic)
				Continued/...

Nitrogen	¼ BSP male fitting or connection for 8mm Polyurethane Tubing Nitrogen Regulator – Two Stage – order Code A00057	Two stage	4-6 bar (60-90 psi)	Minimum 250 litres per minute (Dynamic)	<input type="checkbox"/>
----------	---	-----------	---------------------	---	--------------------------

Connection Type



Push in connection

OR

Push on Connection

Mains Requirements

Electricity Supply	Wall Socket	
240 volts	1 x Three Pin, 13 Amp. Minimum 6A rating	<input type="checkbox"/>

Other Considerations

Do not site the instrument near draughts caused by windows, doors or air conditioning systems

Remember, if you do not have the required regulators you can order them from Don Whitley Scientific::

- Carbon Dioxide Regulator – order Code **A00056**
- Air Regulator – Two Stage – order Code **A01554**
- Nitrogen Regulator – Two Stage – order Code **A00057**

Notes

If an existing unit is being taken in part exchange or is being removed from the laboratory, it must be de-contaminated before DWS staff handle the unit.

Delivery and installation are free of charge (unless otherwise agreed). If our engineers are unable to install the unit and a return journey is necessary, **a charge may be made.**

It is essential that this form is completed and returned, to avoid delay to your installation.

THANK YOU FOR THINKING WHITLEY

Signature	<input style="background-color: white; border: none;" type="text"/>	Title	<input style="background-color: white; border: none;" type="text"/>
Print Name	<input style="background-color: white; border: none;" type="text"/>	Establishment	<input style="background-color: white; border: none;" type="text"/>